

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM  
**LISTING SERVICE**



**LISTING No.** 6911-1615:104

Page 1 of 1

**CATEGORY:** Voice Communication Systems Control Units

**LISTEE:** Bosch Security Systems, 130 Perinton Parkway, Fairport, NY 14450  
Contact: Frank Mioduszewski (585) 678-3368 FAX (585) 678-3263

**DESIGN:** Model EVAX100 and EVAX100E audio adjunct system. The unit is intended to be used in conjunction with separately listed electrically compatible speakers and fire alarm control unit to provide voice communication, paging, evacuation tone signals, and voice alarm signals with voice override. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** Input: 24-30 VAC/DC, Standby: 24 VDC, 7 Ah Battery

**INSTALLATION:** In accordance with listee's printed installation instructions, wiring diagram, applicable codes and ordinances and in a manner which is acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating, and UL label.

**APPROVAL:** Listed as a voice evacuation/communication/audio adjunct system for use with a separately listed electrically compatible fire alarm speakers and control unit. Supervision is dependent upon the fire alarm control panel. Refer to the control panel's listing and installation instructions for proper configurations. Authority having jurisdiction should be consulted prior to installation.

**XL:** **6911-1446:104**

06-07-04



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 28, 2008**

*Listing Expires June 30, 2009*

Authorized By: **BEN HO, Chief**  
*Fire Engineering Division*

